



Weight Rating For NZ Seismic Zones (Soil Class C NZS1170)				
Location	Z factor (NZS4219:2009 Table 3)	Building Importance Level	Clamp Fix Max Unit Weight (Per 4 Roofing Clips)	Top Fix Max Unit Weight (Per 4 Roofing Clips)
Auckland	0.13	1		
Hamilton	0.16	1		
Wellington	0.40	1		
Christchurch	0.30	1		
Invercargill	0.17	1		
Auckland	0.13	2		
Hamilton	0.16	2		
Wellington	0.40	2		
Christchurch	0.30	2		
Invercargill	0.17	2		
Auckland	0.13	3		
Hamilton	0.16	3		
Wellington	0.40	3		
Christchurch	0.30	3		
Invercargill	0.17	3		

STANDARD LIGHT DUTY MOUNT PART NUMBERS (OTHER SIZES AVAILABLE ON REQUEST)		
PART NO.	'L' Top Rail Length in mm	'U' Upright height in mm
CS001.12.1	1200	100
CS001.15.1	1500	100
CS001.18.1	1800	100
CS001.12.3	1200	300
CS001.15.3	1500	300
CS001.18.3	1800	300
CS001.12.4	1200	400
CS001.15.4	1500	400
CS001.18.4	1800	400
CS001.12.6	1200	600
CS001.15.6	1500	600
CS001.18.6	1800	600

RECOMENDED FOR UNITS 80 kg & UNDER



STANDARD CONDENSOR MOUNT		
TYPICAL DETAILS		
DWG No: 2004-CS001-1	11/06/2018	
	SHEET 1 OF 1	A3
	SCALE : 1:20	REV:01
DO NOT SCALE	DIMENSIONS IN MILLIMETERS	